

# **SITE VISIT REPORT**

**For**

**Structural Stability Study of School Building at Patna**



**Department of Civil Engineering**  
**National Institute of Technology Patna**

**Patna – 800 005**



Department of Civil Engineering  
National Institute of Technology Patna  
(An Institute Under Ministry Of HRD , Govt of India New Delhi  
Ashok Rajpath, Patna -800 005(Bihar)

## SITE VISIT REPORT

Name of Client : Principal In-Charge, Christ Church Diocesan School, Patna  
Letter No. : Nil dt 21.06.2021  
MR. No. : 6893dt. 07/07/2021  
Site Visited By : A team of following faculty members and along with other staff members of Civil Engineering Department of NIT Patna visited the above site  
1. Dr. Sanjay Kumar  
Site Visited on : 7<sup>th</sup> july 2021



(Figure No. 1)





(Figure No. 2)



(Figure No. 3)





(Figure No. 4)



(Figure No. 5)

**Recommendation:** Rapid Visual Screening cum Inspection was done for entire building. No structural cracks were seen at any beam column joints. Neither any seepage had been found. The maintenance of the building is satisfactory. So the structure is in good condition no further nondestructive or destructive test is required. However the annual maintenance should be done for more durability and serviceability.



*Dr. Sanjay Kumar*  
12/07/2021  
(Dr. Sanjay Kumar)

Civil Engineering Department